

Tested by NGC Testing Services, 1650 Military Road, Buffalo, NY 14217-1198

Acoustical Testing Laboratory

Approval Date : October 11, 2021

Description	Report No.	dB	Test
STC (Sound Transmission Class)			
Standard	NGC 5021051	37dB	ASTM E90-09 / E413-10
3" Fire rated Can	NGC 5021055	34dB	ASTM E90-09 / E413-10
4" Fire rated Can	NGC 5021056	35dB	ASTM E90-09 / E413-10
5" Fire rated Can	NGC 5021057	37dB	ASTM E90-09 / E413-10
6" Fire rated Can	NGC 5021058	38dB	ASTM E90-09 / E413-10
IIC (Impact Insulation Class)			
Standard	NGC 7021064	33dB	ASTM E492-09(2016)e1 / ASTM E989-18
3" Fire rated Can	NGC 7021068	36dB	ASTM E492-09(2016)e1 / ASTM E989-18
4" Fire rated Can	NGC 7021069	36dB	ASTM E492-09(2016)e1 / ASTM E989-18
5" Fire rated Can	NGC 7021070	37dB	ASTM E492-09(2016)e1 / ASTM E989-18
6" Fire rated Can	NGC 7021071	37dB	ASTM E492-09(2016)e1 / ASTM E989-18