

CONCLUSIONS

The following conclusions represent the judgment of UL LLC based upon the examinations and tests presented in this Report, as they relate to established principles and previously recorded data.

FIRE RESISTANCE PROPERTIES:

It is judged that the luminaire assemblies as described herein are eligible for UL Classification as Luminaire Assemblies Classified for Fire Resistance, when installed in 2 hr rated L500 Series Floor-Ceiling Designs in the UL Fire Resistance Directory incorporating solid wood joists or open-web wood trusses spaced max 24 in. OC, wood flooring and gypsum board ceiling.

CONFORMITY

The assemblies were tested with the furnace temperatures controlled in accordance with the time-temperature curve in the Standard, Fire Tests of Building Construction and Materials, ANSI/UL 263, and the Standard, Standard Methods of Fire Endurance Tests of Building Constructions and Materials, CAN/ULC S101-14.

TEST RECORD SUMMARY

The results of this investigation including construction review and testing indicate that the products evaluated comply with the applicable requirements in the Standards noted below and, therefore, such products are judged eligible to bear UL's Mark as described on the Conclusion Page of this Report.

Standard	Title	Edition or Publication Date	Revision Date
UL 263	Fire Tests of Building Construction and Materials	14	March 2, 2018
ULC S101-14	Standard Methods of Fire Endurance Tests of Building Constructions and Materials	5	June 2014

Test Record by:
KEVIN R. HYLAND
Staff Engineer

Reviewed by:
SHAWN Q. MARSHALL
Staff Engineer

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.